



THE EASTERN SPECIALTY COMPANY

Self-Contained Metering Fundamentals and Introduction to Meter Testing



Prepared by Tom Lawton, TESCO The Eastern Specialty Company

for MEUA Meter School 102 March 3, 2020 9:15 a.m. – 11: 15 a.m. 11:15 a.m. – 12:00 noon

Questions to Answer

- Why do we test?
- How do we test?
- What types of meter tests are there?
- How do utility tests differ from customer request tests?
- What is In-Service Testing?
- How do we know meter tests are good?
- What do we do with the test data?
- What is the electrical theory behind the testing we do?

Why Do We Test?

Our regulatory commissions require us to test meters.

But only for accuracy. State regulatory commissions want electric utilities to ensure that no customer is being billed unfairly and that no subset of customers is being unfairly subsidized by the rest of the rate payers. Some states mandate only accuracy tests and others require demand and time of use accuracy tests.

Any tests beyond accuracy tests are tests that are simply good business practice.



Complaint Testing

Customers always have the right to request a meter test.

Some utilities and some jurisdictions allow for testing at the customer site, others require a test in a laboratory environment.

Some allow the customer to witness the test and others require the utility commission to witness the test.

Utilities must show that the meter tests well and must demonstrate that they have a test program in place to ensure the meters in service are performing well.



General Meter Testing Requirements

- New Meters
 - Manufacturers tests
 - In-house tests on new shipments
- Return to Service Testing
- In-Service Meters
 - Periodic Tests
 - Selective, random, or statistical testing
- Retirement tests
- Testing of related metering equipment





New Meter Testing Programs

- Accept the Manufacturer's Test results
- Perform a Statistical Test of an incoming shipment
- Perform a 100% test of an incoming shipment





Return to Service Testing

- Meters to be returned to service must always (virtually every utility commission requires this) be accuracy tested before being returned to service.
- Best business practices also require that the meter is functionally tested as well.





In Service Testing

Meter Testing for new and in-service meters is specified in ANSI C12.1-2015, *American National Standard for Electric Meters, Code for Electricity Metering*. Most utility commissions use this Standard a reference or the basis for their meter testing requirements.





Test Plans for Meters

Four test plan options available:

- Periodic
- Statistical







Periodic Test Plans

- Periodic
 - Varies by State
 - Example provided by ANSI C12.1:
 - Each Electro Mechanical meter is tested once every 8 years
 - All other Meters are tested every 16 years
 - Appendix D provides details for other meters & devices
 - No guidance for AMI meters



/erage of 12.5% o

8 Years



ted per year

16 Years



Statistical Test Plans The Best Approach

ANSI C12.1-2001 Code for Electricity Metering Guidance

Paragraph 5.1.4.3.3 Statistical sampling plan

"The statistical sampling plan used shall conform to accepted principles of statistical sampling based on either variables or attributes methods. Meters shall be divided into homogeneous groups, such as manufacturer and manufacturer's type. The groups may be further divided into subdivision within the manufacturer's type by major design modifications."

NOTE - Examples of statistical sampling plans can be found in ANSI/ASQC Z1.9, the ANSI version of MIL-STD-414 and ANSI/ASQC Z1.4, the ANSI version of MIL-STD-105.



Why Use a Statistical Testing Plan?

- Focuses testing on the proper meters
- Minimizes number of meters to be tested; usually requires less than 30% of what a periodic testing plan requires
- Provides data and analysis tools for use in understanding what is happening with installed meters or for use in the purchasing of new meters





Homogeneous Population(s)

- The groups or populations being sampled and tested are made up of the same or similar items, items which operate in the same way and were made in the same manner.
- For electric meters, this has traditionally been interpreted as being meters of a specific meter type from a manufacturer (i.e. AB1, J5S, MX, etc.).
- AMR & AMI programs have helped to make the overall populations more homogenous. This makes a utility with AMR & AMI meters better prepared to take advantage of a statistical sampling plan.



Testing of a Meter vs Testing a Site

Test an installation and system and not just a meter!

Test programs may need to involve testing and checking the meter performance as well as checking and testing the installation. This more extensive test check list needs to be done especially for the higher revenue C&I customers.







METER FORMS

1Ø3W with 1 C.T. Single Stator Meter(2VVIØ) - Form 3S 5T Socket

DIAGRAMA Ħ 甲由 Ħ (ALTLOC) e) 60 99

1Ø2W with 1 P.T. & 1 C.T.

Single Stator Meter(2W1Ø) - Form 3S 5T Socket





3Ø3W "∆" with 2 P.T.'s & 2 C.T.'s 2 Stator Meter - Form 5S 8T Socket



3Ø4W "Y" or "A" with 3 C.T.'s "Y" 3 Stator Meter - Form 9S "Δ" 2 Stator Meter - Form 8S





3Ø3W ***Δ*** with 2 C.T.'s 2 Stator Meter - Form 5S 8T Socket



3Ø4W 'Y' with 3 P.T.'s & 3 C.T.'s 3 Stator Meter - Form 9S 13T Socket



1Ø3W with 2 C.T.'s Single Stator Meter(3W1Ø) - Form 4S 6T Socket



3Ø4W "Y" with 3 C.T.'s 2 % Stator Meter - Form 6S 13T Socket

AM

白白 白白

軍田

6

町



1Ø3W or 3W Network with 2 C.T.'s

2 Stator Meter - Form 5S 8T Socket

DIAGRAMD









Meter Testing Traceability

- Test equipment to NIST standards
- Tracking number of meters to be tested per State
 Commission requirements
- Tracking meter test data
 - Meter Records
 - Meter Data Management System (MDMS)



Meter Testing Traceability

- Traceability is defined as ability to link the results of the calibration and measurement to related standard and/or reference (preferably national or international standard) through an unbroken chain of comparisons.
- Calibration is typically performed by measuring a test unit against a known standard or reference.
- Master standard (i.e. gages) are kept by National Measurement Institute (NMI) of each country.



Meter Testing Traceability

- <u>National Institute of Standards and Technology (NIST)</u> provides internal tracking numbers, which are often used as evidence of traceability.
- **WARNING!** NIST does not certify or guarantee that calibration and measurements are correct, nor does it provide any kind of certification of accuracy and calibration. NIST only provides certifications for the work performed by them.

Meter Testing Traceability - Standards





Meter Testing Traceability - Standards

<u>National Standard</u>

In the US, this is maintained by NIST, in Canada by NRC. Not all countries have a National Standards group and even the US does not have a group for every item of interest to an electric utility (e.g. voltage transformers)

<u>Reference/Master Standard</u>

Item of highest metrological quality located at a site where calibration is being conducted.

Transfer Standard

Lower level of Reference Standard and used for calibration of lower level calibration requirements measuring devices.

Working Standard

Lower level of Reference Standard and used for calibration of lower level calibration requirements measuring devices. Should be compared to Master Standard or Reference Standard on regular basis; used for daily checks comparisons of the calibrated devices.



Test Equipment Calibration

Primary Requirement: Traceable to NIST Standards

- Meter Test Boards, Field Test Kits calibrated to a known master standard maintained at Meter Shop.
 - ✓ Some periodicity such as monthly or quarterly
- Reference or Master standard calibrated by outside vendor traceable to NIST or directly by NIST.
 - ✓ Usually annually



Tracking Meter Records

- AMI programs help to update and overhaul meter record systems.
- Having the records for the entire meter population updated allows for a better chance that test data is available to answer questions and that any meter may be selected as part of the sample for testing.





Meter Test Data Tracking

Test data should be tracked throughout meter life

 Certification testing, first article, acceptance testing, in-service (field & shop), retirement

- Meter test data should be linked to meter record data such as meter form, amps, voltage, display type, etc.
- Best time to start to develop the program is before the meters are being installed.
- Accuracy test data is usually collected automatically as new meters are tested in meter shops or cross docks.





Meter Test Data Tracking

- Need to consider tracking non-accuracy functional testing (meter software configuration, service disconnect testing, voltage, etc.)
- Use installation reports to determine if there is any initial concerns about the meters being installed.
- Typical reports that should be available:
 - Failed Meter Report, Project to Date
 - Electric Meters on Network Report





Meter Test Data Tracking System

- System should track meter test results for ease of future reference or for response to public or Utility Commission inquiries.
- Maybe part of Meter Data Management System (MDMS) or a separate Meter Records system.
- Requires discipline in collecting & entering data, especially field tests.



Ohms Law

Voltage = Current times Resistance V = I X R

THE MOST USEFUL AND THE MOST FUNDAMENTAL OF THE ELECTRICAL LAWS



Basic Concepts: Electricity and Water

Comparing Electricity to Water flowing from a hose

- Voltage is the equivalent of the pressure in the hose
- Current is water flowing through a hose (coulombs/sec vs gal/sec). The water in a system is the "charge" (coulombs)
- Impedance(Resistance) is the size of the hose. The nozzle would provide a change in resistance.
- Power is how fast water flows from a pipe (gallons per minute vs kilowatts). Power is a rate of energy consumption



Basic Concepts: Electricity and Water





Practical Electricity



- Ohms Law Examples
 - If V = 20 volts and I = 5 amperes what is the resistance?
 R = V / I = 20 / 5 = 4 ohms
 - If R = 20 ohms and V = 120 volts what is the current?

I = V / R = 120 / 20 = 6 amps

- If I = 10 amperes and R = 24 ohms what is the voltage?
 V = I x R = 10 x 24 = 240 volts
- Problem: If V = 240 volts and R = 6 ohms what is the current?
 I = V / R = 240 / 6 = 40 amps



Power is Voltage x Current

• Power = Voltage x Current = V x I = $I^2R = V^{2/R}$

Voltage (volts):	Current (amps):	Resist.(ohms):	Power:
V=I x R	I = V/R	R = E/I	P=VxI
V=P/I	I = P/V	$\mathbf{R} = \mathbf{P}/\mathbf{I}^2$	$P = I^2 x R$
$V = \sqrt{(P \times R)}$	$I = \sqrt{(P/R)}$	$R = V^2/P$	$P = V^2/R$



- Power = Voltage x Current = $V \times I = I^2 R = V^{2/R}$
 - If V = 20 volts and I = 8 amperes what is the power?

P = V x I = 20 x 8 = 160 watts

• If R = 5 ohms and V = 120 volts what is the power?

 $P = V^{2}/R = 120 \times 120 / 5 = 2880$ watts

- If I = 10 amperes and R = 20 ohms what is the power?
 P = I²R = 10 x 10 x 20 = 2000 watts
 - 1 kilowatt (kW) = 1,000 watts
 - 1 megawatt (MW) = 1,000,000 watts



- ♦ Kirchoff's Voltage Law (KVL)
- The sum of the voltages around a circuit loop is zero.



Resistors in series add

V = V1 + V2 + V3 = I * (R1 + R2 + R3) = I1 * R1 + I2 * R2 + I3 * R3 I = I1 = I2 = I3



Kirchoff's Voltage Law (KVL) – PROBLEM #1



What is the current in the circuit?

What are V1, V2, V3?

I = V / R = V / (R1 + R2 + R3) = 120/(10+20+30) = 2amperes

V1 = I*R1 = 2 *10 = 20 volts V2 = I*R2 = 2 *20 = 40 volts V3 = I*R3 = 2 *30 = 60 volts



- Kirchoff's Current Law (KCL)
- The sum of the currents at a node in a circuit is zero.



I = I1 + I2 + I3

- If Loads are placed in parallel they sum up.
- So does power

$$P = V \times I = V \times I1 + V \times I2 + V \times I3$$



Basic AC Theory Power – The Simple View

E = Voltage (rms)I = Current (rms)PF = Power Factor Power = Watts = $E \times I \times PF$ Power is sometimes referred to as Demand For a 120 Volt service drawing 13 Amps at Unity (1.0) PF, how much power is being drawn? Power = $120 \times 13 \times 1.0 = 1560$ Watts

Sinusoidal Waveforms Only

NO Harmonics



Basic Meter Math Power – The Simple View

For a 120 Volt service drawing 13 Amps at 0.866 PF, how much power is being drawn? Power = 120 x 13 x 0.866 = 1351 Watts



For a 480 Volt service drawing 156 Amps at 0.712 PF, how much power is being drawn? Power = 480 x 156 x 0.712 = 53,315 Watts





Basic AC Theory Power – The Simple View

In the previous example we had:

Power = 480 x 156 x 0.712 = 53,315 Watts

Normally we don't talk about Watts, we speak in Kilowatts

1000 Watts = 1 Kilowatt = 1 kW

Watts / 1000 = Kilowatts

For a 480 Volt service drawing 156 Amps at Unity (0.712) PF, how <u>many Kilowatts</u> are being drawn?



Power = 480 x 156 x 0.712 / 1000 = 53.315 kW



Basic AC Theory Energy – What We Sell

If power is how fast water flows from a pipe, then energy is how much water we have in a bucket after the water has been flowing for a specified time. Energy = Power x Time

1 kW for 1 Hour = 1 Kilowatt-Hour = 1 kWh

Energy (Wh) = $E \times I \times PF \times T$

where T = time in hours

Energy (kW) = (E x I x PF / 1000) x T



Basic Meter Math Energy – What We Sell

For a 120 Volt service drawing 45 Amps at a Power Factor of 0.9 for 1 day, how much Energy (kWh) has been used? Energy = (120 x 45 x 0.9 / 1000) x 24 = 116.64 kWh

For a 240 Volt service drawing 60 Amps at a Power Factor of 1.0 for 5.5 hours, how much Energy (kWh) has been used? Energy = (240 x 60 x 1.0 / 1000) x 5.5 = 79.2 kWh



Basic Meter Math Energy – What We Sell

For a 120 Volt service drawing 20 Amps at a Power Factor of 0.8 from 8:00AM to 6:00PM, and 1 Amp at PF=1.0 from 6:00PM to 8:00AM how much Energy (kWh) has been used? 8:00AM to 6:00PM = 10 hours 6:00PM to 8:00AM = 14 hours Energy = (120 x 20 x 0.8 / 1000) x 10 = 19.2 kWh Energy = $(120 \times 1 \times 1 / 1000) \times 14 = 1.68 \text{ kWh}$ Energy = 19.2 kWh + 1.68 kWh = 20.88 kWh



Basic AC Theory What is VA?

Power was measured in Watts. Power does useful work. The power that does useful work is referred to as "Active Power."

VA is measured in Volt-Amperes. It is the capacity required to deliver the Power. It is also referred to as the "Apparent Power."

Power Factor = Active Power / Apparent Power $VA = E \times I$ PF = W/VA



Basic Meter Math Power – VA

For a 120 Volt service drawing 13 Amps at 0.866 PF

How much power is being drawn? Power = $120 \times 13 \times 0.866 = 1351$ Watts How many VA are being drawn? VA = $120 \times 13 = 1560$ Volt-Amperes





Basic Meter Math Power – VA

For a 480 Volt service drawing 156 Amps at 0.712 PF

How much power is being drawn? Power = $480 \times 156 \times 0.712 = 53,315$ Watts How many VA are being drawn? VA = $480 \times 156 = 74,880$ Volt-Amperes





Basic Meter Math Power – VA

For a 120 Volt service drawing 60 Amps at 1.00 PF

How much power is being drawn? Power = $120 \times 60 \times 1.00 = 7,200$ Watts How many VA are being drawn? VA = $120 \times 60 = 7,200$ Volt Amperes





Basic AC Theory Power Factor = 1.0





Basic Energy Formula

- The essential specification of a watthour meter's measurement is given by the value *K_h*[Watthours per disk revolution]
- The watthour meter formula is as follows:

$$E\left[\text{Watthours}\right] = K_h \left[\frac{\text{watthours}}{\text{disk revolution}}\right] * n\left[\text{disk revolutions}\right]$$

Meter Shop Accuracy Test Demo





Questions to Answer

- Why do we test?
- How do we test?
- What types of meter tests are there?
- How do utility tests differ from customer request tests?
- What is In-Service Testing?
- How do we know meter tests are good?
- What do we do with the test data?
- What is the electrical theory behind the testing we do?

Questions?



Tom Lawton

TESCO – The Eastern Specialty Company Bristol, PA 215-785-2338

This presentation can also be found under Meter Conferences and Schools on the TESCO web site: <u>www.tescometering.com</u>

