



THE EASTERN SPECIALTY COMPANY

SINGLE PHASE METER TESTING OVERVIEW

Prepared by Tom Lawton, TESCO The Eastern Specialty Company









- Why do we test?
- How do we test?
- What types of meter tests are there?
- How do utility tests differ from customer request tests?
- What is In-Service Testing?
- How do we know meter tests are good?
- What do we do with the test data?



WHY DO WE TEST?

The first and most important reason is that this is the fundamental contract we have with our customers – we sell them electricity and they pay the agreed upon price. Our rate payers expect that we are charging them fairly and we make every effort to ensure that we are. So, we perform meter tests.

Because of the importance of this Utility commissions in every state also require some level of meter testing.

But only for accuracy. State regulatory commissions want electric utilities to ensure that no customer is being billed unfairly and that no subset of customers is being unfairly subsidized by the rest of the rate payers. Some states mandate only accuracy tests and others require demand and time of use accuracy tests.

Any tests beyond accuracy tests are tests that are simply considered a "good business practice".



ACCURACY TESTING

The basic accuracy tests puts energy through a meter and the same amount of energy through a traceable standard. That standard is considered 100.0% accurate for the sake of our accuracy test and the ratio of how much energy the meter sees to how much energy the standard sees is the meter accuracy.

Electric meters always come from the factory with a stated accuracy based on exactly this type of test. Typical accuracies might be 99.98% or 99.96%. Typical requirements for residential meters are +/- 2.0% so these meters are far better straight off the manufacturing line than required. Many utilities tighten up these requirements and will not let a meter into the field with any thing more than +/- 0.5%. These new meters are still more than an order of magnitude better than that.



The basic watt hour meter is a marvel in simplicity. The old electromechanical meters can continue to accurately (with better than 99.90% accuracy) measure energy consumption after more than 30 years in an outdoor environment. And they were and continue to be relatively inexpensive (\$20 to \$30). This is pretty incredible.

With electromechanical meters, for every turn of the disk a certain amount of energy passing through the meter (Kh). Count the number of turns and you know how much energy is used over time.

For electronic meters, for every pulse there is a certain amount of energy passing through the meter. Count the pulses after the first one and you know how much energy is used over time.

Modern standards all have pulse outputs and most also provide the comparison with the meter under test.



Landis + Gyr Type MX Electromechanical (1994 to 2009)



- The essential specification of a watthour meter's measurement is given by the value
 K_h[Watthours per disk revolution]
- The watthour meter formula is as follows:

$$E\left[\text{Watthours}\right] = K_h \left[\frac{\text{watthours}}{\text{disk revolution}}\right] * n\left[\text{disk revolutions}\right]$$



TRACEABILITY AND SETUP

However, there is also the accuracy and traceability of the standard to consider as well as the set-up of the test and whether the test is in the meter lab, the meter shop or the field.

Traceability is the ability to trace the calibration of any one dévice back to an international standard.

Typical stated accuracies for standards are 0.04%, 0.02% and 0.01%. In the lab, these same standards typically measure better than 0.005%. That is 50 parts per million in accuracy.

Just because you have all the right equipment though, a bad setup can invalidate any test or calibration whether this is in the field or in a more controlled environment.





tescometering.com

FCIALTY COMPANY





PJLA Calibration Accreditation # 101105



- Traceability is defined as ability to link the results of the calibration and measurement to related standard and/or reference (preferably national or international standard) through an unbroken chain of comparisons.
 - Calibration is typically performed by measuring a test unit against a known standard or reference.
- Master standard (i.e., gages) are kept by National Measurement Institute (NMI) of each country.



- <u>National Institute of Standards and</u> <u>Technology (NIST) provides internal</u> tracking numbers, which are often used as evidence of traceability.
- WARNING! NIST does not certify or guarantee that calibration and measurements are correct, nor does it provide any kind of certification of accuracy and calibration. NIST only provides certifications for the work performed by them.
- NIST is the US National Lab but using NRC out of Canada or any other national lab is also acceptable. We need traceability to an international standard and all these national labs do this.







METER TESTING TRACEABILITY - STANDARDS

<u>National Standard</u>

In the US, this is maintained by NIST, in Canada by NRC. Not all countries have a National Standards group and even the US does not have a group for every item of interest to an electric utility (e.g., voltage transformers)

<u>Reference/Master Standard</u>

Item of highest metrological quality located at a site where calibration is being conducted.

Transfer Standard

Lower level of Reference Standard and used for calibration of lower-level calibration requirements measuring devices.

Working Standard

Lower level of Reference Standard and used for calibration of lower-level calibration requirements measuring devices. Should be compared to Master Standard or Reference Standard on regular basis; used for daily checks comparisons of the calibrated devices.



TEST EQUIPMENT CALIBRATION

Primary Requirement: Traceable to an International Standard

 Meter Test Boards, Field Test Kits calibrated to a known master standard maintained at Meter Shop.

✓ Some periodicity such as monthly or quarterly

- Reference or Master standard calibrated by outside vendor traceable to a national lab (e.g., NIST, NRC) or directly by a national lab.
 - ✓ Usually annually for metering





METER SHOP AND FIELD ACCURACY TESTS





- True Three phase boards multi position and single position
- Series Parallel Boards multi position and single position
- Field Test kits







True Three Phase Boards (TESCO MQB3) Multi-position and Single Position

Apply true three phase voltage and current to electric meters, enabling them to be tested under all possible conditions that may be encountered in the field with TESCO's Three Phase Meter Qualification Board (MQB3).

The MQB3 facilitates the following meter shop functions in high volume:

- New AMI/AMR meters settings check-out
- Meter program updates
- Software revision checking for both the meter and the communications module
- Communications module troubleshooting
- Checking of problem meters for open/shorting.elements





Series Parallel Boards (TESCO MQB) Multi-position and Single Position

Power-up and apply load to electric watt-hour meters for functionality testing with TESCO's multi-position MQBs. These boards assist with AMI Meter Certification process and AMI meter qualification and communication testing.

Available in functional test, series parallel, and true three-phase configurations, these boards can be banked together to provide any number of sockets required. Disconnect testing is standard on all TESCO MQBs and each socket position is designed to accommodate any meter form requested.





Series Parallel Boards (TESCO Cat. 2990) Multi-position and Single Position

The 2990 revolutionizes meter testing by providing full series parallel meter testing in a small, budget-friendly desktop package.

A fully ANSI compliant test board, the 2990 offers complete testing of all meters under the widest range of test conditions. The new waveform generator has all waveforms called out in ANSI C12.20-2015 (pub. 4/2017). All common electromechanical and solid-state meters up to 50 amps can be tested with the 2990 using the single voltage and three isolated current sources.



USIDE TYPICAL TEST SETUPS FOR SHOP AND FIELD

Field Test Kits

As a utility, most revenue comes from large customers who have transformer-rated services. At transformer rated sites the opportunity for something to go wrong is much greater than at a self-contained site. Studies have shown that at transformer-rated sites, most issues are related to wiring, CTs, PTs and other issues. If you want to be sure that the customer is billed correctly and you are not losing revenue, you must test the whole site, not just the meter.

TESCO's all-in-one 6330 Meter Site Analyzer gives you the most versatile site testing tool available in a small, lightweight package. No other test system has the functionality of:

- Complete Site Verification
- CT Testing (ratio with Burden, burden, admittance)
- Meter Testing

HE EASTERN SPECIALTY COMPANY

- Customer Load to 20A
- Load Box to 5A
- Accuracy, Demand, Timed Register, Timed Run, Energy
 Deliveryetering.com





meter, but when all the meter did was measure energy, this meant all we were interested in was an accuracy test. Today's AMI meters may have a disconnect device under the cover, provides a variety of distribution related information including direct voltage and current measurements that can be provided back to the head end. The communication to the meter is

two ways and the meters can be upgraded over the air. The meter can have temperature alerts, tamper

can be recorded, and a host of distribution specific data collected and transmitted. All this functionality

alerts, micro arc detection (hot socket) alerts and last gasp alerts among other alarms. Wave forms

is now becoming part of "meter testing".

accuracy. AMI has changed that completely. We have always tested the functionality of the

Once upon a time meter testing was only about

IS THE METER TEST ALL ABOUT ACCURACY?

IE EASTERN SPECIALTY COMPANY







For transformer rated services the site inspection and verification is far more important than just the meter test. The meter test is only one component of this work and is often the least important of all the steps on the check list.

We are interested in single phase meter testing in this presentation but even at self-contained residential services performing a visual inspection of the site often determines what the issue or issues may be with the site that have nothing to do with the accuracy of the meter.



Test an installation and system and not just a meter!

Test programs may need to involve testing and checking the meter performance as well as checking and testing the installation. This more extensive test check list needs to be done especially for the higher revenue C&I customers.







Customers always have the right to request a meter test.

Some utilities and some jurisdictions allow for testing at the customer site, others require a test in a laboratory environment.

Some allow the customer to witness the test and others require the utility commission to witness the test.

Utilities must show that the meter tests well and must demonstrate that they have a test program in place to ensure the meters in service are performing well.





GENERAL METER TESTING REQUIREMENTS

- New Meters
 - Manufacturers tests
 - In-house tests on new shipments
- Return to Service Testing
- In-Service Meters
 - Periodic Tests
 - Selective, random, or statistical testing
- Retirement tests
- Testing of related metering equipment





- Accept the Manufacturer's Test results
- Perform a Statistical Test of an incoming shipment
- Perform a 100% test of an incoming shipment





RETURN TO SERVICE TESTING

- Meters to be returned to service must always (virtually every utility commission requires this) be accuracy tested before being returned to service.
- Best business practices also require that the meter is functionally tested as well.





Meter Testing for new and in-service meters is specified in ANSI C12.1-2015, *American National Standard for Electric Meters, Code for Electricity Metering*. Most utility commissions use this Standard a reference or the basis for their meter testing requirements.





- Periodic
 - Varies by State
 - Example provided by ANSI C12.1:
 - Each Electromechanical meter is tested once every 8 years
 - All other Meters are tested every 16 years
 - Appendix D provides details for other meters & devices
 - No guidance for AMI meters
 - Generally, average of 12.5% of population tested per year



8 Years



16 Years



ANSI C12.1-2001 Code for Electricity Metering Guidance

Paragraph 5.1.4.3.3 Statistical sampling plan

"The statistical sampling plan used shall conform to accepted principles of statistical sampling based on either variables or attributes methods. Meters shall be divided into homogeneous groups, such as manufacturer and manufacturer's type. The groups may be further divided into subdivision within the manufacturer's type by major design modifications."

NOTE - Examples of statistical sampling plans can be found in ANSI/ASQC Z1.9, the ANSI version of MIL-STD-414 and ANSI/ASQC Z1.4, the ANSI version of MIL-STD-105.





- Focuses testing on the proper meters
- Minimizes number of meters to be tested; usually requires less than 30% of what a periodic testing plan requires
- Provides data and analysis tools for use in understanding what is happening with installed meters or for use in the purchasing of new meters





- The groups or populations being sampled and tested are made up of the same or similar items, items which operate in the same way and were made in the same manner.
- For electric meters, this has traditionally been interpreted as being meters of a specific meter type from a manufacturer (i.e., AB1, J5S, MX, etc.).
- AMR & AMI programs have helped to make the overall populations more homogenous. This makes a utility with AMR & AMI meters better prepared to take advantage of a statistical sampling plan.





- AMI programs help to update and overhaul meter record systems.
- Having the records for the entire meter population updated allows for a better chance that test data is available to answer questions and that any meter may be selected as part of the sample for testing.





Test data should be tracked throughout meter life

 Certification testing, first article, acceptance testing, in-service (field & shop), retirement

- Meter test data should be linked to meter record data such as meter form, amps, voltage, display type, etc.
- Best time to start to develop the program is before the meters are being installed.
- Accuracy test data is usually collected automatically as new meters are tested in meter shops or cross docks.

VIP Task Manag	er Professional User: Adm	ministrator] (DataBase	Media Organization S	olution)								- 0	×	
Elle Tiew Joel	s Help													
ask List Task Tree	Calendar Resource List													
10 . 10	o, o, 7 o, 1	2 d. 11	1 1 12 12	S	Leyout 2	8								
Tack Tree - Fib	au - 7 22		Name		ID Stehm	Correlete	Assigned	Priority	Due Dete	Start Date	6	rish Date		
	The state of the s	Media Organization Sc	aution .			100			08.11.2009	22. 10.2009 12:0	0 05.1	1.2009 17:03		
urrent	0.04	De Project (Mecka Pro	duction Workflow)			155/5			08.11.2009	22. 10.2009 12:0	0 05.1	1.2009 17:03		
		🖯 💣 1. Creating ma	edia content			100.01			03.11.2009	22. 10.2009 16:3	12 05.1	1.2009 17:03		
46	-	Discuss me	edia content with Senior	Editor on a meeting	1 Complete		Dick Nilson	Normal	23.10.2009	22. 10. 2009 16:3	12 23.10	0.2009 17:02	1	
Common		Get dead	nes and build schedules		2 Completes	100.00	Enmanuel Rurich	Low	24.10.2009	22. 10.2009 16:3	24.30	0.2009 17:02	1	
Name		· Gather inf	ormation		3 Completes	-	Daniel Brown	Normal	03.11.2009	22. 10.2009 16:3	12 03.1:	1.2009 17:02		
10		 Have an in 	terview with people		4 - Campletes	a 100.46	Jennifer Bire	Normal	31.10.2009	22. 10.2009 16:3	13 29.10	0.2009 17:03		
Status	Report ontines	and includes of	8	s)	5 Completer	-	Emmanuel Rurich	Low	01.11.2009	22, 10.2009 16:3	13 05.1	1.2009 17:03		
Prority	index of using	THE R P. LEWIS CO., LANSING MICH.				and they			08.11.2009	31, 10, 2009 16:3	01.1	1.2009 16:33		
Actual tree	Data sections			0	Children Denite Alle	nData)Ioca	all Tames Interaction	Themes Internal -	Windows Intern	at Funktion	_	-	-	
Re Date	General	R History		Constant must have a second state of a second state of the second										
Date Flange	😹 🗹 Assignments	🚱 🕢 💌 @ G\Usersi.Dmitry\AppData\Local\Temp\htmCSE7.tmp.htr 🔹 😽 🗙 🚮 Goople												
Date Create	te & Z Atachmerta				Fr Windows 1 h	Date		_	_	_	_	10 •	34	
Date Lost M	R V Notes	<u>^</u>	ag methodus Liv	ung						- 10				
Date States	22 (V) Consists													
Date Comple				100						n - m -	A 4 2	Denne Labor		
By Resource HIP lomet														
Domer	a HTML Iomat													
Assignment	Templates	Default sol												
Department														
Custom Fields		(-	
ET vs. AT		M BURDINGON	× Lose		Fask: #1 -									
Type					riptus:tid=1									
Parked make					General									
Quankly				Generat									1	
Page					came:	Discuss m	iega content with	senor Editor	Tech meeting	10	and the second se			
					stimated time:	Ch Cre			Actual time:	Ch Cr	ming media com			
					Status:	Concietes	4		Camplete:	100 5				
					Due date:	2009-10-2	13				14			
					Atart	22 10 200	9 16:32		Finish:	23.10	2009 17:02			
					late started:	22.10.200	91636		Date complet	ed: 22.10	2009 16:36			
					lesources:	Dick Nilse	00							
			Microsoft Excel	- vip tm export view								-	-	
lications			The second second	- porteran					_					
Charles In	Pro Cha	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	tere Equ	yes poet form	at Tool? Days	Mundow	Heb							
1 a a	W M I M	contrario (102)		3171211	123.	7.11.	· · · · · ·	31 14 4	0 0 1	Tahoma	2.8	- B I	U	
			Dr. Depairs x Of	Ice Live Oreparts *	Corperante *									
	Tèle D	Date Created 1	B9	5 89	B	_								
			AB	C 05		D	E	F	G	н		1	_	
		(No details deplay)	ID	Name		itahus	Complete	Priority	Due Date	a lafo	Assigned	Date Last He	odfie	
		and a second second	1 Not Com	1. formed										
			2 - rask oroup	L- Generality	Com	inted 7	100 N. N		28.09.20		Employee 4	10.08.2000	14.1	
A Material To Them				and the second s			and the Normal		- ALGE 23		and the second sec		10.009 38:27	
Matteriore In	Charte		3		core	eno l	200 1919				Cubiolisie r	11.00.2007		



- Need to consider tracking non-accuracy functional testing (meter software configuration, service disconnect testing, voltage, etc.)
- Use installation reports to determine if there is any initial concerns about the meters being installed.
- Typical reports that should be available:
 - Failed Meter Report, Project to Date
 - Electric Meters on Network Report





- Test equipment to an International standard
- Tracking number of meters to be tested per State Commission requirements
- Tracking meter test data
 - Meter Records
 - Meter Data Management System (MDMS)





- System should track meter test results for ease of future reference or for response to public or Utility Commission inquiries.
- Maybe part of Meter Data Management System (MDMS) or a separate Meter Records system.
- Requires discipline in collecting & entering data, especially field tests.





- Why do we test?
- How do we test?
- What types of meter tests are there?
- How do utility tests differ from customer request tests?
- What is In-Service Testing?
- How do we know meter tests are good?
- What do we do with the test data?



QUESTIONS AND DISCUSSION

Tom Lawton

President

tom.lawton@tescometering.com



TESCO – The Eastern Specialty Company

Bristol, PA

215-228-0500

This presentation can also be found under Meter Conferences and Schools on the TESCO website: www.tescometering.com

> ISO 9001:2015 Certified Quality Company ISO 17025:2017 Accredited Laboratory