





TESCO METERING

Testing 1% Transformers Methodology & Motivation

New York State Electric Meter Engineers
Committee – Fall Meeting 2025

Prepared By: Tom Lawton
Date: September 17, 2025





Introduction

To become the primary outside metering resource for all electric utility customers

- Terminology
- Why testing is critical for extended range transformers
- CT Testing Overview
- Knopp True Primary Reference Comparison
- 1% CT Construction/Design
- What to Test and Why
- True Error, Knopp Testers
- Questions





Terminology

- **Ref:** Reference Transformer
- **TUT:** Transformer Under Test
- **RCF:** Ratio Correction Factor
- **TCF:** Transformer Correction Factor
- **Minutes:** 1 degree = 60 minutes
- **RF:** Thermal Rating factor, sometimes expressed as a % (100% = 5A) or a number (4 = 20A), is based on thermal rating
- **Accuracy Class (Acc):** Percentage of allowed error, ex. 0.3Acc means +/- 0.3% accuracy
 - Knopp gives a measured accuracy class during test, this should be below the nameplate of CT. Ex. 0.21 shown, <0.3 so within spec





Why testing is critical for extended range transformers

- IEEE C57.13-2016 does not specify accuracy below 5% but many manufactures are beginning to claim measurements down to 1%
 - *These claims should always be validated*
- Reduced inventory variety
 - *A 600:5 with a RF of 3 makes anything less than 600 redundant for stocking purposes or unique applications*
- Most of the present 1% CT's are 0.15 Accuracy Class, so an upgrade of range is an upgrade in accuracy as well.
 - *When compared to 0.3 instrument transformers*



<https://ritzusa.com/wp-content/uploads/2020/11/Low-Voltage-Extended-Range-Current-Transformers.pdf>



CT Testing Overview

Understanding the Parallelogram




Figure 2, IEEE C57.13-2016

- Transformers when under test must comply within their respective class bounds for phase and ratio.
- The class they fit within also depends on the current value, all must match nameplate at 5amps on the secondary, but some (0.3 in example) can double when below an RF of 1.0

IEEE Std C57.13-2016
IEEE Standard for Requirements for Instrument Transformers

Table 8—Standard accuracy class for metering service and corresponding limits of transformer correction factor and ratio correction factor [0.6 to 1.0 power factor (lagging) of metered load]^c


Metering accuracy class	Voltage transformers (at 90% to 110% rated voltage)		Current transformers					
	Minimum	Maximum	At <u>100%</u> rated current ^a		At <u>10%</u> rated current		At <u>5%</u> rated current	
			Minimum	Maximum	Minimum	Maximum	Minimum	Maximum
0.15S ^b	—	—	0.9985	1.0015	—	—	0.9985	1.0015
0.15 ^b	0.9985	1.0015	0.9985	1.0015	—	—	0.9970	1.0030
0.15N	—	—	0.9985	1.0015	0.9970	1.0030	—	—
0.3S	—	—	0.9970	1.0030	—	—	0.9970	1.0030
0.3	0.9970	1.0030	0.9970	1.0030	0.9940	1.0060	—	—
0.6	0.9940	1.0060	0.9940	1.0060	0.9880	1.0120	—	—
1.2	0.9880	1.0120	0.9880	1.0120	0.9760	1.0240	—	—

^a For current transformers, the 100% rated current limit also applies to the current corresponding to the continuous thermal current rating factor.

^b Previously defined in IEEE Std C57.13.6.

^c Other accuracy requirements may be specified and should be included on the nameplate.

Table 8, IEEE C57.13-2016



<https://ritzusa.com/wp-content/uploads/2020/11/Low-Voltage-Extended-Range-Current-Transformers.pdf>


$Acc = \text{Greater of } Acc1 \text{ vs } Acc2$

$$Acc1 = |RCF - 1| \times 100$$

$$Acc2 = \left| RCF - 1 - \frac{\beta}{2600} \right| \times 100$$

$\beta = \text{Phase Difference in Minutes}$

- **Given:** RCF 0.9975, Mins +8, Nameplate 0.3Acc
- $Acc1 = 0.25$ *Pass or Fail?*
- $Acc2 = 0.558$
- Accuracy Class = 0.558, *Pass or Fail?*
- *Fail @ 100%, Pass at 10%*





TESCO METERING



Knopp True Primary Reference Comparison

Secondary Injection

- Mobile, can be done in field
- Can determine other CT parameters for use diagnosing site issues
- Medium Accuracy


Direct Primary Measurement

- Mobile, can be done in field
- Testing can be done in conjunction with metering
- Medium-Low Accuracy


True Primary Reference Comparison

- Static, lab based
- Testing with variety of parameters (purchasing/Eng.)
- High to Very High Accuracy

Understanding a True Primary Test



- A True Primary test, pushes the entire primary current through the CT to be tested, and a reference transformer.
- Both of these output their secondary current which are each read. The TUT must push its secondary Current through a Burden which will affect its output



Understanding a True Primary Test

TUT


Reference

The difficulty without a trick...


5.0000A vs 5.0200A

0.38Acc


Understanding a True Primary Test




- Notice the Reference and TUT are opposing one another in the center...
- What happens to opposing currents in a branch?
- Summed Vector (opposite direction is subtractive)
 - *At Knopp, we call this the "Error" Vector*



Understanding a True Primary Test



- So, we have devised a test that tests a CT in the way that it will be used rather than secondary injection
- And, we have used “Electrical Trig” to increase the accuracy of the measurement vs measuring primary to secondary



Understanding RCF: An Example

$$RCF = \frac{\text{Reference Current}}{\text{TUT Current}}$$

$$RCF = \frac{\text{Measured Ratio}}{\text{Marked Ratio}}$$

Take a 600:5 for example:

- Marked ratio: $\frac{600A}{5A} = 120$
- Primary Current = 600A
 - Ref Current = 5.00A
 - TUT Current = 4.99A

Calculate RCF by Current, and by Ratio

$$\text{RCF by Current: } \frac{5.00A}{4.99A} = \mathbf{1.002}$$

$$\text{Ref Measured Ratio: } \frac{600A}{5A} = 120$$

$$\text{TUT Measured Ratio: } \frac{600A}{4.99A} = 120.24$$

$$\text{RCF by Ratio: } \frac{120.24}{120} = \mathbf{1.002}$$

Understanding TCF: An Example


From before, RCF = 0.9975, and phase = +8mins:

$$TCF = RCF - \frac{\beta}{2600}$$

$$TCF = 0.9975 - \frac{8}{2600}$$


$$TCF = 0.9944$$

This is similar to RCF, but accounts for phase error as well and is what is typically used to correct for a CT's error if only one number can be given



1% Construction And Design

B-H Curve





- A Transformer is a magnetic device that reacts to current passing through a core
- The Core builds up a magnetic field
- In turn, the magnetic field creates a secondary current
- The Core can only contain so much field until it is saturated
- The area in graph is the CT core losses
- The consistency of the permeability slope yields a more linear transformer


Transformer Magnetic Operation

“Bathtub Curve”


(RCF vs Rating Factor)



- Take note of initial perm and saturation
- Increased burden increases secondary voltage, hence Bsat is hit faster




- In order to go lower, and be more accurate, more exotic materials were chosen.
 - **Blue** represents normal silicon steel, found in power transformers.
 - **Red** represents nickel and amorphous alloys
- Softer new materials have a lower saturation, but tend to be more linear and better low end
- Note the initial permeability slopes...





What to Test & Why


How CT's Operate



- CT's should never be run near saturation, they are a near zero flux device.
- If there was a true zero burden (including windings), no core losses, CTs would have almost no B-H curve as the ratio would be perfectly cancelled out
- This is why initial perm plays such a large role in material selection.
- Initial perm can be a bit erratic as its almost entirely material and material processing, so CT to CT can differ depending on process control.

Be sure to Test Upper and Lower

- Without tight enough Core material process control, CT's can have variability at the low end even with "higher end" Materials
- Shrinking the core can also improve the low end by shifting the bathtub to the left. This can result in the high end starting to come close to saturation on larger burdens
- Softer Cores also can be more sensitive to magnetization due to the reduced B scale



<https://www.gevernova.com/grid-solutions/equipment/instrument-transformers/revenuesense>


<https://www.artech.com/en/ieeeansi-low-voltage-instrument-transformers>


<https://new.abb.com/medium-voltage/apparatus/instrument-transformers-and-sensors-id/outdoor-application/ansi-outdoor-instrument-transformers>



True Error

Knopp Testers





KCTS-8000XA



KCTS-8000X



Questions and Discussion

Tom Lawton

President

tom.lawton@tescometering.com

TESCO Metering *Bristol, PA*

215.228.0500




This presentation can also be found under Meter Conferences and Schools on the TESCO website: tescometering.com

ISO 9001:2015 Certified Quality Company
ISO 17025:2017 Accredited Laboratory



TESCO METERING



TESCO METERING

Thank You!