



TESCO METERING

Meter Safety

TESCO's Meter School
TESCOOL
July 20-23, 2025

July 23, 2025
10:30 AM -- 12:00 PM
Brennan Wood - APCO

YOU are responsible for your own safety on the job!

SAFETY FIRST



**Safety
Starts
Here**

Think Safe...
Work Safe...
Be Safe

Hazard #1: Falls and Falling Objects

- Approximately 19,565 people die in the U.S. annually due to injuries caused by unintentional falls.
- Slips, trip and fall injuries cost employers approximately \$40,000 per incident.
- About 9.2 million people were treated in emergency rooms for fall-related injuries last year.






Hazard #2: Chemical Exposure

- Breathing of contaminated air is the most common way that workplace chemicals enter the body.
- The CDC estimates more than 32 million workers in the US are potentially exposed to chemicals that can be absorbed through the skin.
- Roughly 860,000 illnesses resulting from chemical exposure occur in the workplace every year.

Hazard #3: Fire Hazards

- A structure fire is reported approximately every minute of every day and results in approximately \$12 billion in property loss every year.
- According to the National Fire Protection Association, there were an estimated 3,340 fires in U.S. office properties per year.





Hazard #4: Electrical Hazards

- The construction industry accounts for 52% of all electrical fatalities in the US workplace.
- Most incidents and fatalities were caused by direct worker contact with overhead power lines and contact with machines, tools, and hand-carried metallic objects.
- Engineers, electricians, and overhead line workers top the list of professionals who are most exposed to electrical hazards.
- The most common type of work to result in an electrocution is routine work involving repair and maintenance.

Hazard #5: Repetitive Motion Injury

- According to the Bureau of Labor Statistics, Repetitive Motion Injury cases accounted for 33% of all worker injury and illness cases
- In the U.S., the costs associated with RMI's are estimated at \$20 billion every year according to OSHA




How Dangerous is Metering?

Electricity is Organized Lightning – George Carlin



Any Voltage without current will not kill you, but any voltage with current can kill you.



What is Electric Shock?

Electric shock is a flow of electrical current through a person's body.

Damage to the skin or internal organs as a result of contact with electrical current is an electric injury.


Electric shock can cause a minor twinge, mild to serious injuries, or death, depending on the circumstances and voltage.

What is Electric Shock?

The human body conducts electricity well, so it travels through the body with ease.


People can incur organ damage even if there is only a minor burn on the skin.

The most common areas injured by electric shock are the heart, muscles, and brain.




Current	Effect
1 mA	Barely noticeable
16 mA	Maximum current before you can't let go
20 mA	Paralysis of respiratory muscles
100 mA	Ventricular fibrillation starts
2 Amps	Cardiac standstill and organ damage

Total nonfatal work injury and illness rates, private industry




Source: U.S. Bureau of Labor Statistics.

Number of fatal work injuries by employee status



Number of work-related deaths from exposure to environmental heat, 2011–21



What is an Arc Fault?

An Arc Fault is a type of electrical fault that results from the breakdown of an insulating medium between two conductors where the energy is sufficient to sustain an arc across open air.




What is an Arc Flash?

An Arc Flash is an event that occurs when electrical current flows through an air gap between conductors.

An arc flash can cause extreme amounts of light and immense heat of more than 19,000° C. This can result in an explosive pressure wave called an arc blast.

These forces combine to create a hazardous condition that can vaporize metal, destroy equipment, and pose a significant hazard to anyone in the vicinity.





Arc Flash can also be caused by:

Common causes are the accidentally touching of a test probe to the wrong surface or a slipped tool.

Arc Flash can also be caused by:

Sparks due to breaks or gaps in the insulation of the conductors.

Equipment failure, improper insulation, substandard parts or substandard material.

Magnetic fields created by dust, corrosion and other impurities can cause ionization of the surrounding air creating a path for a resulting flash.



Personal Protection Equipment (PPE)

This is why we wear our PPE.



Personal Protection Equipment (PPE)

Personal Protective Equipment

- Leathers
- Rubber Gloves
- Face Shield
- FR Clothing
- Safety Shoes
- Insulated Tools



Personal Protection Equipment (PPE)


Arc Flash PPE categories range from 1 to 4

Arc Flash PPE Category level 1 is the lowest risk level.

Arc Flash PPE Category level 4 is the highest risk level



How Bad Can Things Get?



Many thanks to Dominion Power

<https://youtu.be/2Xoyb9M5-EA>

Rubber Gloves and FR 4:10

Meter enclosure shorted out 10:48

Back feed from generator 19:34

As You Approach the Service

- **Moisture or water** inside the meter face and/or rust on the meter base, such as leaks at the service entry cable or other meter base components.
- **Missing knockouts** on the meter base.
- **Broken or cracked conduit** at the electrical meter or meter hubs.
- **Loose connections** of the meter base, including meter pulling away from the building wall and loose mounting screws.
- **Evidence of tampering** at the meter, missing meter seal.

We've seen house fires start when a screw from a loose meter box fell into the meter and caused a dead short.




- Always approach an electrical service with caution and while wearing your full PPE. Why?
- Never stand directly in front of the meter when removing the meter
- Before you even open the box or get the cover off....
 - Live box
 - Bees
 - Other live animals
- Broken Seal
- Cover dropping off
- Uneven terrain





Field Audits/Troubleshooting/Testing



Issues to Look For Once the box is Open



- Open line side connection to the meter socket.
- Missing neutral connection to the center lug in the meter socket
- Cross wiring between the test block and the meter socket.
- Hidden jumper, line to load – diversion on both legs.
- Dead short, phase to ground on the load side of one leg of the socket.
- Partial short, phase to ground on the load side of one leg of the socket.
- Evidence of burning or arcing at the meter base.

- Socket Pullers
- Volt meters
- Insulated tools
- Specialized tools



- Be Careful
- Assume the box is live
- Assume there is something live in the box
- Treat electricity with respect
- Treat all meter boxes with respect



As with any industry, adhering to and complying with OSHA standards and company safety policies is a vital step in preventing injuries. OSHA standards that apply to the utilities industry include:

- Electrical – General Requirements (1910.303)
- Electrical – Wiring Methods (1910.305)
- Electric Power Generation, Transmission, and Distribution (1910.269)
- Personal Protective Equipment, Subpart I (1910)
- Fall Protection (1926.501)
- Hazard Communication (1910.1200)
- Respiratory Protection (1910.134)
- Lockout/Tagout (1910.147)



Personal Protection Equipment



- Issues that you may have seen in your service territory?
- Do you have issues with non-metering personnel performing metering operations?
- Unique issues in your service territory?
- Safety Issues not discussed?
- Are your meter techs typically putting safety first?

A safety poster with a yellow and black diagonal striped border. On the right side is a silhouette of a worker wearing a yellow hard hat, yellow safety glasses, a yellow high-visibility vest over a black long-sleeved shirt, black trousers, and yellow safety boots. The worker has their arms crossed. To the left of the worker is a list of ten safety rules, each preceded by a yellow diamond containing a black number. The title 'SAFETY RULES' is at the top left in large, bold, yellow and black letters.

SAFETY RULES

- 1 You are responsible for your own safety and safety of others.
- 2 Wear personal protective equipment necessary for the job.
- 3 Always use equipment/tools/machinery safely and properly.
- 4 Lift properly using your legs and not your back.
- 5 Keep your work area clean.
- 6 Wear appropriate and safe work clothing and footwear.
- 7 Report any unsafe conditions.
- 8 Clean up spills immediately.
- 9 Report all injuries.
- 10 No alcohol or drugs to be used or allowed on company property.



Dan Falcone ConnectDER

This presentation can also be found under Meter
Conferences and Schools on the TESCO web site:
www.tescometering.com

