



THE EASTERN SPECIALTY COMPANY

TEST SWITCH OPERATION & ACCESSORIES

Prepared by Dan Hollow
Rocky Mountain Regional Sales Manager,
TESCO – The Eastern Specialty Company



for Rocky Mountain Meter School
March 16, 2022
10:30AM-11:30 AM



THE EASTERN SPECIALTY COMPANY

INTRODUCTION / BIOGRAPHY

Dan has worked for TESCO since 2015, and was originally hired to sell the Meter Manager Meter Asset Management Software and then was given the Rocky Mountain Region Sales Territory in late 2016. He now sells the TESCO products in 4 states (CO, WY, UT, MT, ID, AZ, and the western half of KS, NE, SD, and ND). Dan has been working in the utility industry since 1988 and began his career in the utility industry as the Test Department Supervisor for Aptech. In 1992 he accepted an outside sales position with Aptech and has been in outside sales ever since. Dan has worked for companies such as UTS/Itron, Datamatic, SmartSynch, Metrum Technologies/Aclara, and TESCO. Primary background is in Electronics.

Dan has worked in the technology industry since 1980 and has worked in other industries such as Banking Equipment, Industrial CNC Controls, Process Controls and Flight Simulation Equipment prior to working in the utility industry.




THE EASTERN SPECIALTY COMPANY

PURPOSE:

To acquaint the attendees with the use and purpose of Meter Test Switches

Course Breakdown of Topics:

- Using Test Switches
- Meter Test Switch Specifications
- Meter Test Switch Configurations
- Meter Test Switch Accessories
- Pre-Wired Transformer Rated Enclosures






THE EASTERN SPECIALTY COMPANY

TYPICAL SELF CONTAINED SERVICE

- Typically found in residential metering
- Meters are capable of handling the direct incoming amperage
- Meter is connected directly to the load being measured
- Meter is part of the circuit
- When the meter is removed from the socket, power to the customer is interrupted






THE EASTERN SPECIALTY COMPANY

TRANSFORMER RATED SERVICE

- Meter measures scaled down representation of the load.
- Scaling is accomplished by the use of external current transformers (CTs) and sometimes voltage transformers or PTs).
- The meter is NOT part of the circuit
- When the meter is removed from the socket, power to the customer is not effected.





THE EASTERN SPECIALTY COMPANY

TRANSFORMER RATED SERVICE

9S Meter Installation with 400:5 CT's

SOURCE
PHASE A



400A

PHASE B



400A

LOAD

PHASE C



400A






- Testing current transformers while they are in service can be a dangerous operation if certain safety procedures are not followed. The secondary loop of a current transformer must **NEVER BE OPENED** when service current is present in the primary. When there is current in the primary, and the secondary of a current transformer is open circuited, the voltage across the secondary can rise to hundreds and even thousands of volts, creating an extremely dangerous situation. The open CT secondary voltage magnitude varies with CT design and primary
- current flow. The high voltage that is present on the open secondary of an energized current transformer generates two great hazards. The first hazard is **ELECTRICAL SHOCK TO TESTING PERSONNEL**. The second hazard is **THE BREAKDOWN OF THE CURRENT TRANSFORMER INSULATION**. Both hazards can be avoided provided that the secondary of the current transformer is never opened. The safest current transformer installations for testing are those that have a Test Switch as part of the secondary loop. A Test Switch is a device that will facilitate inserting instrumentation in the current transformer secondary loop without the danger of opening the circuit.



THE EASTERN SPECIALTY COMPANY

TYPICAL CONNECTIONS FOR COMMON METER FORMS





THE EASTERN SPECIALTY COMPANY

TEST SWITCH SPECIFICATIONS

- ANSI C12 Definitions
- Test Switch Materials
- Plating
- Barriers
- Wiring Connections
- What to look for
- Covers





ANSI C12.9 TEST SWITCH DEFINITIONS

AMERICAN NATIONAL STANDARD

ANSI C12.9-2011

For Test Switches and Jacks for Transformer-Rated Meters

1 Scope

This standard is intended to encompass the dimensions and functions of meter test switches used with transformer-rated watt-hour meters in conjunction with instrument transformers and test plugs used in conjunction with the test switch.

2 Definitions

2.1 short-circuiting switch

A single-pole double-throw (make-before-break) transfer switch used to transfer current away from the meter.

2.2 test jack

A spring-jaw receptacle in the current element of a test switch that provides a bipolar test connection in the metering current circuit without interruption of the current circuit.

2.3 test jack switch

A single-pole single-throw disconnect switch used in conjunction with a test jack to provide a parallel current path during normal operating conditions.

2.4 test plug

A bipolar mating plug to a test jack for inserting instrumentation into the metering current circuit.

2.5 voltage switch

A single-pole single-throw switch used to open or close a voltage circuit.

3 Standard ratings

3.1 Current

The current rating shall be 20 A minimum.

3.2 Voltage

The voltage rating shall be 300 V or 600 V.

4 General requirements for test switches

4.1 Material and workmanship

The test switch and its components shall be substantially constructed of suitable material in a workmanlike manner.

4.2 Nameplates

Nameplates are not required on these test switches, but a manufacturer's identifying marking (such as catalog number, trademark, etc.) shall be stamped, printed, affixed, or cast in a convenient place on each test switch. When required, a warning label indicating hidden internal jumpers should be affixed.


4.3 Movable parts

Movable conducting parts such as blade hinges shall be held in place by locknuts or pins or their equivalent, arranged so that a firm and secure connection will be maintained at any position of the switch blade.



THE EASTERN SPECIALTY COMPANY

ANSI C12.9 TEST SWITCHES





ANSI C12.9 GENERAL TEST SWITCH SPECIFICATIONS

1.1 Insulating barriers

When a voltage switch is installed adjacent to current switch or to another voltage switch at a different potential then for safety considerations the two switches shall be separated by an insulating barrier as indicated in figures 1 through 3. Barriers may be an integral part of the base, a separate part fastened to the base, or an integral part of each individual switch section.

1.2 Wiring terminals and test clips

1.2.1 Wiring terminals

Test switches shall be provided with suitable wiring terminals for the connection of AWG No. 14 to AWG No. 8 secondary conductors.

1.2.2 Test clips

Facilities for attaching test clips shall be provided on the terminals or on the wire binding screws.

1.3 Mounting holes

Mounting holes (two minimum) shall be of the dimensions shown in figures 1 through 3.

1.4 Cover

1.4.1 General

An insulated cover shall be available for the test switches and if used shall be held in place by cover studs. The cover may be made of glass, plastic or other suitable non-conducting material, but shall not exceed the maximum dimensions shown in figures 1 through 3. When the cover is in place, all switches shall be in a closed position.

1.4.2 Cover holes

The diameter of the cover-stud holes shall be 0.281 in., located as shown in figures 1 through 3.

1.4.3 Cover studs

Removable cover studs with suitable provisions for sealing shall be available for use in each instrument-transformer-meter test switch in the positions indicated in figures 1 through 3. The diameter of these studs shall not exceed 0.25 in. Standard instrument-transformer-meter test switches shall be provided either with or without cover studs.

1.5 Acceptable spacings

The minimum acceptable spacings shall be as indicated in table 2.

Table 2 – Minimum acceptable spacings

Voltage between parts involved (V)	Minimum spacings from live parts to			
	Parts of opposite polarity*		Grounded metal**	
	Over surface (in.)	Through air (in.)	Over surface (in.)	Through air (in.)
0-300***	0.750*	0.375*	0.500	0.375
301-600	1.250*	0.750	1.000	0.500

*To be acceptable at other than wiring terminals, through-air and over-surface spacings of 0.375 in between parts of opposite polarity shall withstand a special dielectric strength test at 6 000 V, 60 Hz, for 1 min.

**To be acceptable at other than wiring terminals, through-air and over-surface spacings of 0.375 in between current-carrying parts and cast-metal enclosure or grounded metal, where indentation or deformation of the overall enclosure will not affect spacings, shall withstand a special dielectric strength test at 6 000 V, 60 Hz, for 1 min.

***300 V spacings apply to a 600 V test switch, if the phase-to-neutral voltage does not exceed 300 V for spacings: (1) from neutral to phase-voltage parts, and (2) from neutral to grounded metal.



THE EASTERN SPECIALTY COMPANY

TEST SWITCH CONFIGURATIONS

- Layout
- Handle Colors
- Reversed vs. Normal Potentials
- Current Links
- Base Sizing
- Barrier Locations

REV	DESCRIPTION	DATE	APPR.
1	PENDING CUSTOMER APPROVAL	6/18/2011	SFS

(3) CURRENT LINKS

NOTES:

- HANDLE COLORS AS FOLLOWS:
1 ORANGE; 2 RED; 3 BLACK; 4 YELLOW; 5 GREEN;
6 BLACK; 7 BROWN; 8 BLUE; 9BLACK; 10 WHITE
- SWITCH MATERIAL FULL HARD COPPER
- PLATING- BRIGHT TIN
- SWITCH CAN BE SUPPLIED WITH OR WITHOUT CLEAR COVER AND CAPTIVE HARDWARE. FOR SWITCH WITH COVER, CATALOG NUMBER TO BE 909884-C

FORM	BACKING	OTHER	ONE SIDE	TWO SIDES	THREE SIDES	FOUR SIDES	DATE	BY	CHKD BY	DATE	REV	DESCRIPTION
							6/16/2011	SFS				

10 POLE TEST SWITCH ASM	909884	1 OF 1
-------------------------	--------	--------




THE EASTERN SPECIALTY COMPANY

TEST SWITCH ACCESSORIES

- Test Plugs
- Safety Covers
- Test Switch Isolators

On installations that contain Test Switches, test leads terminated with a test switch safety test probe (test plug) should be used for CT testing. This provides a “make-before-break” connection to prevent accidental opening of the current transformer secondary loop.





THE EASTERN SPECIALTY COMPANY

ANSI C12.9 TEST JACK SPECIFICATIONS

4.6 Provision for test plugs

Each double-pole short-circuiting current switch shall incorporate a test jack which is designed to permit the insertion of a test plug. The test-jack switch can be either in the left-hand or the right-hand position. In order to assure proper mating with the test plug the test jack shall conform to Figure 4.




Figure 4 – Test switch typical cross section

Table 1 – Test switch dimensions

TEST SWITCH DIMENSIONS			
DIMENSION	MINIMUM	PREFERRED	MAXIMUM
S	0.900	1.200	1.250
W	0.125	0.140	0.175
X	0.430	0.500	0.550
D	1.280	1.350	N/A
Y			0.188



THE EASTERN SPECIALTY COMPANY

ANSI C12.9 TEST PLUG SPECIFICATIONS

1 General requirements for test plugs

1.1 Materials and workmanship

The test plug shall be constructed with an insulated handle providing an anti-slip gripping area and a barrier to help prevent the user's gloved hand from slipping into contact with the test switch.




Figure 6 – Typical test plug

Notes:

- (1) When the insertion guide takes the form of Section B-B Alternate #1, then for a switch with a slot width W_{min} , the switch Jaws shall not be separated by more than $Y_{max} = 0.188''$ when inserted.
- (2) If a positive stop is provided on the probe blade to limit insertion depth of the probe to M by bottoming out against S of the switch, then L may exceed L_{max} provided $M < D_{min} - S_{max} = 0.030''$.

Table 3 – Test plug dimensions

TEST PLUG DIMENSIONS			
DIMENSION	MINIMUM	PREFERRED	MAXIMUM
L	1.100	1.200	1.260
M	0	0.140	0.175
R	0.090	0.110	0.120
R1	n/a	n/a	0.156
T	0.100	0.130	0.156
G	0.040	0.125	0.175





THE EASTERN SPECIALTY COMPANY

FOR UTILITIES NOT CURRENTLY USING TEST SWITCHES





THE EASTERN SPECIALTY COMPANY

PRE-WIRED TRANSFORMER RATED ENCLOSURES

- Cover Types
- Wiring
- Sockets

REV	DESCRIPTION	DATE	APPR
1	RELEASE FOR CUSTOMER APPROVAL	7/11/2012	SFS

MARWELL 8 TERMINAL METER BLOCK

TESCO TEST SWITCH PIN 909955

4 11/16"

12 1/4"

20"

TESCO LABEL

TESCO LABEL

TESCO TEST SWITCH PIN 909955 MOUNTED ON HIGH BRIDGE

COVER LABEL 5948T72 "CAUTION HIGH VOLTAGE"

WIRE SCHEDULE		
ITEM	COLOR	DESCRIPTION
1	BLACK	10AWG THHN STRANDED WIRE
2	-	
3	YELLOW	
4	-	
5	WHITE	
6	-	
7	BLACK	
8	BLACK	
9	YELLOW	
10	YELLOW	

FORM	REVISED	OTHER	DATE	BY	CHKD	DATE	BY	DATE	BY	DATE	BY
101	1		08/01/12	SFS							


NOTES -

- MATERIAL - 16GA G90 GALVANIZED STEEL. STATIONARY LATCH AND SWING LATCH ARE STAINLESS STEEL.
- FINISH - ANSI 70 GREY POWDER COAT, 3 MIL THICKNESS MIN. BLOCK SUPPORTS AND BRIDGE SUPPORTS ARE UN-PAINTED.
- ELECTRICAL KNOCKOUTS:
 - (2) 3/4" + 1" + 1-1/4" ONE EACH SIDE
 - (1) 3/4" + 1" + 1-1/4" CENTERED LOW IN BACK
 - (3) 3/4" + 1" + 1-1/4" IN THE BOTTOM
 - (1) 1/4" + 5/8" + 1/2" (2) IN THE BOTTOM
- 2-1/2" HUB OPENING WITH FOUR #12-24 TAPPED HOLES WITH CLOSURE INSTALLED
- ONE 1/4-20 X 1" PEM STUD FOR MECHANICAL GROUND LUG.
- FOUR 3/16" DEEP MOUNTING EMBOSSEMENTS WITH 5/16" DIA. KO FOR MOUNTING.



THE EASTERN SPECIALTY COMPANY

QUESTIONS?





THE EASTERN SPECIALTY COMPANY

3 QUIZ QUESTIONS MULTIPLE CHOICE

1. Which type of metering service typically has a test switch?

- A. Self Contained
- B. Transformer Rated
- C. Gas

2. Why would you want to reverse the potentials on test switch?

- A. Aesthetics
- B. To use multiple voltages
- C. To de-energize the potential blades when open for safety

3. What is the purpose of a current link on a test switch?

- A. To enable connection of the test jack and shunt in the current pair to complete the current loop.
- B. To connect the current pairs to the potentials
- C. To eliminate the need for barriers between the poles





THE EASTERN SPECIALTY COMPANY

MORE QUESTIONS AND DISCUSSION



Dan Hollow

Rocky Mountain Regional Sales Manager

dan.hollow@tescometering.com

TESCO – The Eastern Specialty Company

Bristol, PA

303.810.6528

This presentation can also be found under Meter Conferences and Schools on the TESCO website: tescometering.com

ISO 9001:2015 Certified Quality Company
ISO 17025:2017 Accredited Laboratory