



## TESCO – THE EASTERN SPECIALTY COMPANY

Canal Street and Jefferson Avenue  
Bristol, PA 19007

Date: 02/01/13

### OPERATING INSTRUCTIONS – CATALOG NO. 326 LOAD BOX

#### **Before connecting any leads to the Catalog No. 326:**

1. Determine the voltage of service
2. Move Full Load/Light Load switch to “OFF” position
3. Set current select switch to desired test amps
4. Connect current and potential leads to the Catalog No. 326 Load Box and meter under test

**CAUTION: NO SWITCHING OR CHANGING OF CURRENT LEADS SHOULD BE MADE UNLESS THE FULL LOAD/LIGHT LOAD SWITCH IS FIRST PLACED IN THE OFF POSITION.**

Make potential and current connections to two-wire energy source and meter under test according to your company’s meter test diagrams.

Set Full Load/Light Load switch to desired position.

Perform watt-hour meter test according to your company’s testing procedures.